


| | µBrick CHANNELS | | PRIORITY | |
|--------------------------------------|---------------------------|---------|-------------|--------------|
| | Awning | Blind | | |
| Window cleaning > Disable - Active > | Move up | Move up | Highest | BLOCKING |
| m/s Alarm 1 - Active > | Awning UP | X | ↓ | |
| YES/NO Alarm 2 - Active > | Awning UP | X | | |
| Lux Alarm 3 - Active > | Awning DOWN | DOWN | Lowest | |
| Behaviour at end of all alarms > | Depending on sun position | UP | | |
| SETPOINTS | | | No priority | NON BLOCKING |
| Setpoint 1: exterior temperature | DOWN | 80% | | |
| Setpoint 2: interior temperature | DOWN | DOWN | | |



Window cleaning > Highest priority !!