



# Gateway configuration manual

## PROFINET Slave -

## KNX TP

## EK-BN1-TP

**Indice**

Scope of the document.....	3
1 Product description.....	3
1.1 Main functions.....	4
1.2 Technical data.....	4
1.3 Supply.....	5
1.4 System requirements for configuration software .....	5
1.1 Certifications .....	5
2 Switching, display and connection elements.....	6
3 Configuration and commissioning .....	8
4 Profinet protocol general information .....	9
4.1 Tecnology.....	9
4.2 Profinet CBA .....	9
4.3 Profinet IO .....	9
4.4 Addressing .....	9
4.5 Real-time (RT) .....	10
4.6 Isochronous real-time (IRT).....	10
5 Configuration software.....	11
5.1 Memory image structure .....	12
5.2 Creating a new project or modifying a saved project.....	13
5.3 Software Options .....	14
5.4 Communication parameters.....	15
5.5 KNX communication object configuration.....	17
5.6 Profinet registers configuration .....	19
5.7 Configuration update.....	20
6 Warning.....	23
7 Other information.....	23

## Scope of the document

This document describes the gateway (protocol converter) Profinet Slave – KNX TP. The gateway finds its ideal application in the integration of KNX devices over an Ethernet network in a Profinet-based automation system (e.g.: Siemens PLC) for homes and buildings. This product belongs to a broad line of ekinex® gateways designed to meet the needs for integration of the building automation most widely used protocols, based on serial, Ethernet or proprietary infrastructures. For further informations about the available technical solutions, please visit [www.ekinex.com](http://www.ekinex.com).

## 1 Product description

The ekinex® Profinet Slave EK-BN1-TP gateway is a KNX modular unit for panel mounting. It allows you to exchange informations with one master devices over an Ethernet network through Profinet protocol. The ekinex gateway acts as Profinet slave. The informations exchanged over the Profinet network are updated over the KNX network by means of a twisted pair (TP) communication cable.

The device manages a two-way data stream: the Profinet registers can be cyclically read and their value sent as a communication object over the KNX TP network through a multicast communication to configured group addresses. The data update over the KNX network can be done cyclically and/or on event of change of the data acquired by the Profinet network.

Likewise, the ekinex gateway can make requests to cyclically readings KNX communication objects or acquire their values during data exchange over the bus. Cyclically or on event of change of the communication objects, data are written on the Profinet registers of one or more configured devices.

As for KNX communication, 1-bit, 1-byte, 2-byte and 4-byte communication objects can be acquired: internal conversion functions allow you to convert the informations from and to 16-bit floating point values (DPT 9.xxx).

Configuration is performed through a PC application software which communicates through the integrated Ethernet port. The application software CGEKB1TP is available for download at [www.ekinex.com](http://www.ekinex.com).

## 1.1 Main functions

The gateway acts as a bidirectional protocol converter. Data streams are the following:

- Profinet network – Register writing: the writing command is issued to the gateway by the Profinet master. The values of the read registers are stored in a 1440-byte volatile memory buffer (“Profinet image memory”).
- KNX TP network – Sending of writing multicasting frames to configured group addresses. Data can be sent cyclically over the bus (configurable refresh time), on event of change of the data contained in the “Profinet memory image”, or both cyclically and on change. Internal conversion functions to the most common types of KNX Datapoints are present.
- KNX TP network – Multicasting frame listening from configured group addresses (with selectable filters on the area or network of interest) or cyclical sending of read request frames. The values of the acquired communication objects are stored in a 1440-byte volatile memory buffer (“KNX image memory”). This buffer is independent from the “Profinet image memory” buffer.
- Profinet network – Register reading from one or more KNX slave devices by Profinet master’s request.

## 1.2 Technical data

Characteristic	Value
Power supply	8...24 Vac 12...35 Vdc
Power Absorption	At 24 Vdc: 3,5 VA
Application area	dry indoor environment
Environmental conditions	<ul style="list-style-type: none"><li>• Operating temperature: - 40 ... + 85°C</li><li>• Stock temperature: - 25 ... + 55°C</li><li>• Transportation temperature: - 25 ... + 70°C</li><li>• Relative humidity: 93% non-condensing</li></ul>
Programming elements	1 pushbutton and 1 LED (red) on the front
Display elements	4 status LEDs + 1 Ethernet connector LED
Configuration elements	1 1-way microswitches <ul style="list-style-type: none"><li>• Microswitch A: OFF normal mode; ON Boot mode</li></ul>
Safety class	II
Installation	35 mm DIN rail (according to EN 60529)
Protection degree	IP20
Dimensions (WxHxD)	82 x 75 x 35 mm
Profinet/Ethernet interface (IEEE 802.3)	
Connector	RJ45, minimum cable category: 5E
KNX TP interface	
Communication port	KNX TP (twisted pair), 9600 baud, electrically isolated from power supply and RS485 communication port
Power supply	SELV 30 Vdc through bus KNX
Current absorption from bus	< 13 mA

### 1.3 Supply

The supply includes the device and terminal blocks to connect to the KNX bus. An instruction sheet is also supplied within the package.

### 1.4 System requirements for configuration software

Configuration and commissioning of the ekinex® gateway must be performed using the application program CGEKB1N1TP, available for download at [www.ekinex.com](http://www.ekinex.com).

The PC where the application program is installed must meet the following requirements:

- Desktop o laptop PC with Ethernet IEEE 802.3 port.
- 32/64 bit operating system, Microsoft Windows® XP, 7, 8.0, 8.1 e 10.



.NET Framework 4.0 system library installation is required.

### 1.5 Certifications

Compliance with the European directives is certified by the CE symbol on the product label and on the documentation.

## 2 Switching, display and connection elements

The device is equipped with a pushbutton and a KNX programming LED, with a status LED and terminal blocks for KNX network connection. A port for RJ45 connector for Profinet network connection and device configuration via Ethernet as well as one 1-way microswitches are also present.




Figure 1 - Switching, display and connection elements

1)	KNX bus line terminal blocks
2)	KNX programming pushbutton
3)	KNX programming LED
4)	Power supply terminal blocks
5)	1-way microswitch A
6)	Ethernet port
7)	Ethernet port LED
8)	Device status LED
9)	Profinet communication LED
10)	KNX communication LED
11)	Device error LED

Command elements

- Pushbutton that switches between normal mode and KNX physical address programming.

1-way microswitches

- A - OFF: normal mode active. ON: Boot mode active

Display elements

The device can run according to two operating modes: Normal mode (configuration loaded, Profinet and KNX communication running) and Boot mode (no configuration or still loading configuration).

LED	Normal mode	Boot mode
Green LED (8) – Device status	Slow blinking (~1 Hz)	<b>ON:</b> device on <b>OFF:</b> device off
Yellow LED (9) – Profinet communication	Blinks when a frame is received on the Ethernet port	<b>Fast blinking:</b> no configuration <b>Very slow blinking (~0,5 Hz):</b> loading configuration.
Yellow LED (10) – KNX communication	Blinks when a frame is received.	<b>Fast blinking:</b> no configuration <b>Very slow blinking (~0,5 Hz):</b> loading configuration.
Yellow LED (11) – Device error	<b>ON:</b> at least one Profinet request did not get a correct answer <b>OFF:</b> no error	<b>Fast blinking:</b> no configuration <b>Very slow blinking (~0,5 Hz):</b> loading configuration.
Green LED (7) – Ethernet port	<b>ON:</b> Ethernet connector plugged <b>OFF:</b> Ethernet connector unplugged	<b>ON:</b> Ethernet connector plugged <b>OFF:</b> Ethernet connector unplugged
Red LED (3) – KNX programming	<b>ON:</b> physical address programming mode on <b>OFF:</b> physical address programming mode off	<b>Fast blinking:</b> no configuration <b>Very slow blinking (~0,5 Hz):</b> loading configuration.



In the current version of the device, both KNX physical address programming and configuration download must be performed through the configuration program: for KNX physical address please refer to “Communication parameters” paragraph, “ID Device” parameter.

### 3 Configuration and commissioning

The device configuration requires the following tools:

- The documentation of the Profinet master
- The physical parameters of the Ethernet communication for BACnet IP (IP address, subnet mask, gateway, port, delays)
- CGEKN1TP application software to properly configure the gateway
- Knowledge of the ETS automation project, with particular attention to communication objects and group addresses passing on the bus during the multicast communication between sensors and actuators.



Configuration and commissioning of the ekinex® gateway require specialized skills about KNX networks and knowledge of the specific ETS automation project. In order to acquire such skills, it is essential to attend trainings and workshops organized at KNX-certified training centers. For further information: [www.knx.it](http://www.knx.it).

## 4 Profinet protocol general information

Profinet (Process Field Net) is a communication protocol based on Industrial Ethernet according to IEEE 802.xx directive.

### 4.1 Tecnology

There are three different protocol levels:

- TCP/IP for Profinet CBA, with about 100ms of reaction time
- RT (Real-time) protocol for applications based on Profinet IO and Profinet CBA, with up to 10ms cycle time
- IRT (Isochronous Real-time) for applications based on Profinet IO in systems with cycle time inferior to 1ms.

### 4.2 Profinet CBA

A Profinet CBA (Component Based Automation) system consists of several automation components. The components are described through a PCD file (Profinet Component Description) written in XML language. The basic idea of Profinet CBA is that an automation system can be divided into completely stand-alone subsystems but with an identical or slightly different structure. Every component is usually controlled by a specific number of inputs. Inside the component, a control program performs the component's specific function and generates the corresponding outputs, which are then sent to another controller.

### 4.3 Profinet IO

The peripheral interfacing is implemented by Profinet IO protocol.

Profinet IO defines the whole data exchange between master and slave devices, besides the parameter settings and diagnostics. Profinet IO is a protocol designed to facilitate a fast data exchange between Ethernet-based field devices and is ideal for applications with cycle time not greater than 10ms.

A Profinet IO based system consists of the following devices:

- An IO controller, which controls the communication (master)
- Field IO devices (slaves), monitored and controlled by the master
- An IO supervisor, typically a networked PC software, which manages the parameter settings and slave diagnostics.

The characteristics of an IO device (slave) are described in a GSD file (General Station Description) written in XML language, issued by the device manufacturer. The GSD file gives the supervisor the tools to plan the configuration of the Profinet IO system.

### 4.4 Addressing

Each module in a Profinet network has three addresses:

- A MAC address (physical address)
- An IP address
- A device name, e.g. a name which identifies the device at a logical level inside the system configuration

MAC and IP are addresses typical of TCP/IP based devices. The MAC address changes only if the device is replaced, while IP is a dynamic address. The device name is a static address.

## 4.5 Real-time (RT)

In Profinet IO protocol, process data and alarms are always transmitted in real-time (RT). RT, in Profinet, is based on IEEE and IEC specifications, which allow the execution of real time tasks only for a limited time within the bus cycle time.

RT communication is the base for Profinet IO data exchange. Real time data are treated with a greater priority than TCP/IP or UDP/IP data; this kind of data exchange allows to achieve cycle times inferior to 1ms.

## 4.6 Isochronous real-time (IRT)

IRT enabled devices can perform a data exchange with cycle time from hundreds of microseconds to few milliseconds. The main difference between IRT and RT is that IRT communication is more deterministic: in this latter one, it is possible to determine with precision the cycle starting time. Following cycles can have a maximum jitter of 1 microsecond, which make IRT communication ideal for motion control applications.

## 5 Configuration software

The ekinex® configuration software CGEKB1N1TP allows you to perform the following operations:

- Selection of physical address of the device over the KNX TP network;
- Selection of Ethernet parameters;
- KNX network: communication objects definition and relative group addresses to be acquired;
- KNX network: communication objects definition and relative group addresses to be sent over the KNX network;
- Profinet network: creation of GSD file to import in master's configuration
- Firmware and/or configuration update.

The application program consists in multiple modal windows called "forms": each form must be closed before accessing the following form. The buttons on the main form (see Figure 2 – Main form of the application program) are ordered according to the proper sequence to follow in order to perform a correct configuration.




Figure 2 – Main form of the application program

Starting from the main form, by accessing the *About...* window, you can check the current version of the installed program.



Figure 3 – About form



Please visit the section about communication gateways on [www.ekinex.com](http://www.ekinex.com) in order to check the current version of the application program and download the latest version.

## 5.1 Memory image structure

The proper configuration of the device refers to a support volatile memory area where the acquired data are temporarily copied, both on Profinet and KNX side: this memory area is divided into 2 buffers, “Profinet image” and “KNX image”, each one composed of 1440 bytes.

Each support byte can be individually addressed (see *Position* field in *KNX Set Access* form) or you can target a specific support bit in each buffer (*Bit Mode* field in *KNX Set Access* form).

As shown in figure, the same address can refer to both buffers:

- “Profinet image” used in *KNX Set Access* form for writing frames.
- “KNX image” used in *KNX Set Access* form for reading frames.




Figure 4 – Support memory with “KNX image” and “Profinet image” buffers



The proper addressing of the support buffers must be manually performed by the user, based on the size of the data to be acquired. Overlapping support data may end up in a protocol converter malfunction.

## 5.2 Creating a new project or modifying a saved project

The application program allows you to create a new configuration or open an existing one using the buttons called *New Configuration* and *Open Configuration* (see Figure 2 – Main form of the application program): the configuration files are stored on the hard drive in XML format.




Figure 5 – Create new configuration form




Figure 6 – Create new configuration form

In order to duplicate an existing project, you must find the project folder containing the XML files and copy them in a new folder. Project files can be found by the following path:



“C:\Program Files(x86)\Ekinex\Compositor\_CG-EK-BN1-TP\Projects”. Once the project has been duplicated, simply restart the application program and open the form *Open configuration* (see Figure 6 - Open configuration form): you will see the name of the duplicated project in the list of available configurations.

### 5.3 Software Options

The *Software Options* form allows you to select a different language for the application program.



**Figure 6 – Options form, Language tab**

## 5.4 Communication parameters

In this section we define the basic communication parameters for the KNX TP network and for Ethernet connection. Ethernet connection is required in order to both perform the configuration update on the device and for Profinet communication.




Figure 8 – Set communication form

You can access the form by pressing the *Set Communication* button in the main form (see Figure 2 – Main form of the application program).

Description of fields in *Set communication* form.

Parameter name	Values	Description
<b>KNX</b>		
Type	KNX TP	Type of connection used for KNX communication. The parameter has a constant value "KNX TP". The device supports KNX communication over a twisted pair communication cable.
<b>PROFINET</b>		
IP ADDRESS		IP Address (4-octet format) assigned to the device. Each octet is set in an Edit box. Default IP Address is: <b>192.168.2.205</b> . This is the address assigned to the device before the first configuration or after a complete restore.
SUBNET Mask		Subnet mask assigned to the device.
GATEWAY		Gateway address used for Ethernet communication. The gateway can be enabled or disabled through the control check-box placed at the right side of the field.
Port	<b>34964</b>	Port used for Profinet communication

<b>Parameter name</b>	<b>Values</b>	<b>Description</b>
PROFINET Name of Station		Profinet device name
Number Byte IN		Number of input bytes of Profinet node
Number Byte Out		Number of output bytes of Profinet node

## 5.5 KNX communication object configuration

In this section we define communication objects sent or acquired over the KNX network. You can access the form by pressing the *KNX Access* button in the main form (see Figure 2 – Application program main form).




Figure 9 – KNX Set Access form

The form contains a configurable grid. Each record allows you to assign the properties for each communication object exchanged over the KNX network. In order to make the management of a significant number of data easier, after selecting a record it is possible to delete it from the project, insert a new record in a specific position and perform copy/paste of a previously configured record.

### Description of fields in KNX Set Access form

Field name	Values	Description
N		Progressive number of the configuration record
Enable	checked / unchecked	Configuration record enabling. If a record is disabled, the corresponding data points will not be acquired or changed over the KNX bus
Source Address		In case of writing frames (field APCI=write) the physical address may correspond to the physical address of the gateway ( <i>Device ID</i> field in the <i>Set Communication</i> form), in the format Area.Line.Address (each field must be separated by a dot). In case of reading frames (field APCI=read), <i>Source Address</i> acts as a filter. Through this field you can acquire datapoints of all lines over the KNX bus (0.0.0 value) or you can select one specific line (e.g. 4.3.0) or a single device identified by a specific physical address (e.g. 4.3.1).
Dest/Group		A Group Address (2-level, 3-level or free structure) or a Physical Address can be set. In case of a group address the fields must be separated through a “/”, while in case of physical address the separator will be a “.”.
APCI	read / write	The “read” option is used to send a request in order to read a communication object over the KNX bus. The “write” option must be selected if you want to change the value of a communication object over the KNX bus. Other services can be configured by editing the value of the corresponding service. The name used in the field refers to a 4-bit code (APCI = Application Layer Protocol Control Information) which defines the type of service required in KNX communication standard.
Priority	System/ Urgent / Normal / Low	KNX frames priority. In multicast communication (exchange of frames from/to group addresses), the default priority is Low.
Format	None / Swap16 / Swap32 / Swap All / Int to Float / Float to Int / Float 16 to Float 32	In case of a frame containing a data (in response to a reading request frame APCI = read), the Format field determines the data type conversion from the received frame to the support internal memory area. In case of a writing frame (APCI = write), the Format field determines the data type conversion from the support internal memory area to the frame.
Extended	checked / unchecked	Enables extended frame format for KNX communication (cEMI = Common Extended Message Interface)

Field name	Values	Description
ReTest	<b>checked</b> / unchecked	Enables the re-send of a frame in case of wrong response message
OnCMD	<b>checked</b> / unchecked	Not used
OnChange	<b>checked</b> / unchecked	Event which enables the automatic sending of command frames over the KNX bus when the data on the Profinet device changes their values.
OnTimer	<b>checked</b> / unchecked	Event which enables the cyclical sending of command frames over the KNX bus.
Poll Time		Cyclic poll time (in ms) when OnTimer event is enabled.
Position	Value in range [0...1439]	<p>Position of the first byte where a data is stored, in the internal support memory buffer. In case of a record where APCI=read, <i>Position</i> refers to the “KNX image” buffer; in case of APCI=write, <i>Position</i> refers to the “Profinet image” buffer.</p> <p>Please refer to the paragraph concerning the structure of the memory image to perform a correct addressing and avoid overlaps between the two data buffers.</p>
Bit Mode	No / 0 / 1 / 2 / 3 / 4 / 5 / 6 / 7	Position, inside the first byte of the internal support memory buffer, where a 1-bit data is stored.
Lenght		Size (in number of bytes) of the data stored inside the internal memory.
Mnemonic		Text to comment the record and/or the datapoint over the KNX bus.

If *OnChange* field is selected, *OnTimer* is selected and *Poll Time* ≠ 0, the gateway will send the commands both cyclically and on change of the data acquired over the Profinet network.



If *OnChange* and *OnTimer* fields are not selected, the gateway will only store the communication objects exchanged through the multicast frames over the KNX network (“sniffer” function).

Conversion types of internal data selectable through *Format* field:

Conversion	APCI = read	APCI = write
None	The value of the communication object is transferred in raw mode to the “KNX image” buffer and sent as register to the Profinet network.	The value of the communication object acquired over the Profinet network and stored in the “Profinet image” buffer is transferred in raw mode as communication object over the KNX network.
Swap16	16-bit swap inside the stored data	16-bit swap inside the stored data
Swap32	32-bit swap inside the stored data	32-bit swap inside the stored data
Swap All	All bit swap inside the stored data	All bit swap inside the stored data
Int to Float		The integer value acquired over the Profinet network is converted to a 2-byte (DPT 9.xxx) floating point value in order to be sent as communication object over the KNX network.
Float to Int	The 2-byte (DPT 9.xxx) floating point communication object value is converted to integer.	
Float 16 to Float 32	The 2-byte (DPT 9.xxx) floating point communication object value is converted to a 32-bit floating point value (according to standard IEEE 754).	

## 5.6 Profinet registers configuration

By pressing “Profinet XML” button you can access to the form that creates the GSD XML file, which contains the information about the data to be exchanged between the Profinet master and the connected KNX devices. This file will have to be imported in the Profinet master configuration program.




Figure 10 - PROFINET XML File name form

## 5.7 Configuration update

The implemented configuration and possibly the updated firmware can be downloaded by pressing the *Update Device* button in the main form of the application program (see Figure 2 – Main form of the application program).

There can be 2 possible update sequences, the first in case the IP address assigned to the device is unknown, the second in case the IP address is known.




Figure 12 - Update configuration form




Figure 13 – Download options form

### Sequence to follow in case of unassigned or unknown IP address:

- Power off the device
- Set the 1-way microswitch A (see Figure 1 – Switching, display and connection elements) to ON position
- Power on the device
- Connect PC and device by means of an Ethernet cable. Make sure that the PC's network parameters are consistent with the IP address assigned to the device in Boot Mode **192.168.2.205**. Otherwise, change the PC's network settings
- Write the IP address **192.168.2.205** inside the Update Configuration form (see Figure 12 – Update configuration form)
- Press *Ping* button; if you correctly applied the procedure, the text "*Device found!*" will appear
- Press *Next* button
- Select the desired options (see Figure 13 – Download options form): firmware update, configuration update or both
- Press *Execute update firmware* button
- When all operations are completed (see Figure 14 – Update in progress) shut down the device
- Set the 1-way microswitch A (see Figure 1 – Switching, display and connection elements) to OFF position
- Power on the device

If the sequence is successful, this means that firmware and/or configuration has been correctly downloaded on the device.




Figure 14 - Update in progress

Sequence to follow in case of known IP address:

- Power on the device with PC and device connected by means of an Ethernet cable
- Provide the device IP address (see Figure 12 – Update configuration form). Make sure that the PC's network parameters are consistent with the IP address assigned to the device. Otherwise, change the PC's network settings
- Press *Ping* button; if you correctly applied the procedure, the text "*Device found!*" will appear (see Figure 12 – Update configuration form)
- Press *Next* button (see Figure 12 – Update configuration form)
- Select the desired options (see Figure 13 – Download options form): firmware update, configuration update or both
- Press *Execute update firmware* button
- When all operations are completed (see Figure 14 – Update in progress) the device automatically switches back to Normal mode.

If the sequence is successful, this means that firmware and/or configuration has been correctly downloaded on the device.



It is recommended to update the firmware when a new version of the application program is installed or when configuring the device for the first time.

In case the update procedure goes into PROTECTION mode (see Figure 15 – Update error, "Protection" mode), you may want to check the following:




Figure 15 – Update error, "Protection" mode

- Repeat the update sequence
- Reboot your PC
- When running the program on a Virtual Machine, close it and rerun the program using the primary OS
- When using Windows 7 or later, make sure the user has administrator privileges
- Pay attention to firewall settings
- Check LAN configuration



In case of manual firmware update, replace “Sim67818.sim” file in the system folder “C:\Program Files (x86)\Ekinex\Compositor\_CG-EK-BN1-TP\Master”. After replacing, open *Update configurazione* form (see Figure 12 – Update configuration form) in the application program and start the proper sequence.

## 6 Warning

- Installation, electrical connection, configuration and commissioning of the device can only be carried out by qualified personnel.
- Opening the housing of the device causes the immediate end of the warranty period.
- ekinex® KNX defective devices must be returned to the manufacturer at the following address:

EKINEX S.p.A. Via Novara 37, I-28010 Vaprio d'Agogna (NO) Italy.

## 7 Other information

- This application manual is aimed at installers, system integrators and planners
- For further information on the product, please contact the ekinex® technical support at the e-mail address: [support@ekinex.com](mailto:support@ekinex.com) or visit the website [www.ekinex.com](http://www.ekinex.com)
- KNX® and ETS® are registered trademarks of KNX Association cvba, Brussels

© EKINEX S.p.A. 2015. The company reserves the right to make changes to this documentation without notice.